



IEEE Std 430™-2017

(Revision of IEEE Std 430-1986)

Errata to IEEE Standard Procedures for the Measurement of Radio Noise from Overhead Power Lines and Substations

Developed by the

Transmission and Distribution Committee

of the

IEEE Power and Energy Society

Correction Sheet

3 December 2020

STANDARDS

Copyright 2020 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved. Published 3 December 2020. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

After the subclause labeled "9.1 Introduction," please insert the following subclause, which had been previously omitted:

9.2 Measurement procedure

For measuring radio-noise levels (30 MHz to 1000 MHz) from a substation, the following differences in procedures from those presented in Clause 8 apply:

- At each test site, the radio-noise levels at approximately 73.5 MHz and 150 MHz shall be measured. A frequency spectrum shall be measured at the test site that gave the highest levels at 73.5 MHz.
- Either a dipole or broadband antenna may be used in accordance with the discussion in 6.3.1.1 c).

3 December 2020 STD22394E