

IEEE Std 844™ -2000  
(Revision of  
IEEE 844-1991)

# Errata to **IEEE Recommended Practice** **for Electrical Impedance, Induction,** **and Skin Effect Heating of Pipelines** **and Vessels**

Sponsor

**IEEE Industrial Applications Society**  
of the  
**Petroleum and Chemical Industrial Committee**

*Correction Sheet*  
**Issued 15 August 2005**

Copyright © 2005 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved. Published 2005.  
Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

**Page 10, 4.4.1.5, equation (2) should be:**

$$T = (D - d)/2 \quad (2)$$

**Page 13, 4.4.2.2.1 Dielectric spark test, the first sentence should read as follows:**

During the manufacturing each unit length of cable shall withstand, without failure, a spark test in accordance with Table 2 below and Clause 900 of UL 1581-1997.

**Page 13, the title of Table 2 should read as follows:**

Table 2—Dielectric spark test

**Page 25, 7.3.2 Induction heating systems, the last sentence in the paragraph should read as follows:**

Table 6 lists the limitations and advantages of induction heating.

**Page 25, 7.3.3 Skin-effect heating systems, the last sentence in the paragraph should read as follows:**

Table 6 lists the limitations and advantages of skin-effect heating.